

Facility Name \_\_\_\_\_ Pool or Spa \_\_\_\_\_

Monthly period _____ to _____, 2____		Test when opening & closing + every 4 hours											Daily				Weekly			Comments					
Time	Date	Free Cl/Br-	Comb. Cl	pH	Free Cl/Br-	Comb. Cl	pH	* ORP *	Free Cl/Br-	Comb. Cl	pH	* ORP *	Free Cl/Br-	Comb. Cl	pH	Flowrate AM	Flowrate PM	Clarity**	Temp		Alkalinity	Ca Hardness	CYA	Sat Index	
	1																								
	2																								
	3																								
	4																								
	5																								
	6																								
	7																								
	8																								
	9																								
	10																								
	11																								
	12																								
	13																								
	14																								
	15																								
	16																								
	17																								
	18																								
	19																								
	20																								
	21																								
	22																								
	23																								
	24																								
	25																								
	26																								
	27																								
	28																								
	29																								
	30																								
	31																								

\*\*Clarity Good, Marginal, Poor: Good means very clear; marginal means cloudy but main drain still visible, poor means drain obscured

Parameters Cl 2-8 ppm; Comb Cl ≤ 0.5ppm; Br 2-10 ppm; pH 7.2-7.8; Alk 60-220 (varies by pool); Sat index -0.5 to + 0.5; CYA <100ppm; ORP >650

